



Pace Analytical Services, LLC-Fairfield

1275 Bloomfield Avenue, Fairfield, NJ 07004 (973) 227-0422



ANALYTICAL RESULTS

STANDARD DELIVERABLES FORMAT

WORK ORDER NUMBER: 2410677

Warren Glen Academy

Project: Warren Glen Academy

A handwritten signature in black ink, appearing to read "S. Pradhan", with a horizontal line underneath.

Sudip Pradhan
Laboratory Director

All Results meet the requirements of the National Environmental Laboratory Accreditation Conference and/or State specific certifications as applicable.

Report Date: Sep 18, 2024



Pace Analytical Services, LLC-Fairfield

Client: Warren Glen Academy
45 County Rd 519
Bloomsbury, NJ 08804

Order ID Number: 2410677
Received: 09/06/2024 16:00

Project: Warren Glen Academy
Report Date: 09/18/2024 15:00

Contact: _One Time Client Agra
Customer Service Rep: Victor G. Cervantes

Analytical Results Summary

Sample Number	Analyte	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units	Reg Limit
---------------	---------	--------	----------	----------	--------	------	-----	----	-------	-----------

2410677-01	Drinking Water		Field Blank							Collected : 09/06/2024 7:58
Total Metals										
Copper	EPA 200.8	09/16/24 14:49	09/16/24 14:49	<0.00600	U	0.00600	mg/L	1.3 (5)		
Lead	EPA 200.8	09/16/24 14:49	09/16/24 14:49	<0.00200	U	0.00200	mg/L	0.015 (5)		

2410677-02	Drinking Water		WF 1 Left Side DD							Collected : 09/06/2024 7:48
Total Metals										
Copper	EPA 200.8	09/16/24 14:53	09/16/24 14:53	0.0114		0.00600	mg/L	1.3 (5)		
Lead	EPA 200.8	09/16/24 14:53	09/16/24 14:53	0.00611		0.00200	mg/L	0.015 (5)		

2410677-03	Drinking Water		WF 2 Right Side							Collected : 09/06/2024 7:49
Total Metals										
Copper	EPA 200.8	09/16/24 15:40	09/16/24 15:40	0.0536		0.00600	mg/L	1.3 (5)		
Lead	EPA 200.8	09/16/24 15:40	09/16/24 15:40	0.00801		0.00200	mg/L	0.015 (5)		

2410677-04	Drinking Water		WF 3 Right Tap							Collected : 09/06/2024 7:50
Total Metals										
Copper	EPA 200.8	09/16/24 15:44	09/16/24 15:44	0.0520		0.00600	mg/L	1.3 (5)		
Lead	EPA 200.8	09/16/24 15:44	09/16/24 15:44	<0.00200	U	0.00200	mg/L	0.015 (5)		

2410677-05	Drinking Water		Staff Room Sink							Collected : 09/06/2024 7:51
Total Metals										
Copper	EPA 200.8	09/16/24 16:13	09/16/24 16:13	0.0517		0.00600	mg/L	1.3 (5)		
Lead	EPA 200.8	09/16/24 16:13	09/16/24 16:13	<0.00200	U	0.00200	mg/L	0.015 (5)		

2410677-06	Drinking Water		Nurse's Office Sink 1 BR							Collected : 09/06/2024 7:52
Total Metals										
Copper	EPA 200.8	09/16/24 16:17	09/16/24 16:17	0.222		0.00600	mg/L	1.3 (5)		
Lead	EPA 200.8	09/16/24 16:17	09/16/24 16:17	0.00555		0.00200	mg/L	0.015 (5)		

2410677-07	Drinking Water		Nurse's Office Sink 2							Collected : 09/06/2024 7:54
Total Metals										

Report Date: Sep 18, 2024

See FootNotes on Last Page of Sample Results



Pace Analytical Services, LLC-Fairfield

Client: Warren Glen Academy
45 County Rd 519
Bloomsbury, NJ 08804

Order ID Number: 2410677
Received: 09/06/2024 16:00

Project: Warren Glen Academy
Report Date: 09/18/2024 15:00

Contact: _One Time Client Agra
Customer Service Rep: Victor G. Cervantes

Analytical Results Summary

Sample Number	Analyte	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units	Reg Limit
2410677-07	Drinking Water		Nurse's Office Sink 2		Collected : 09/06/2024 7:54					
Total Metals										
	Copper	EPA 200.8	09/16/24 16:22	09/16/24 16:22	0.225		0.00600		mg/L	1.3 (5)
	Lead	EPA 200.8	09/16/24 16:22	09/16/24 16:22	0.00540		0.00200		mg/L	0.015 (5)
2410677-08	Drinking Water		Lower Kitchen Sink 1		Collected : 09/06/2024 7:55					
Total Metals										
	Copper	EPA 200.8	09/16/24 16:26	09/16/24 16:26	0.488		0.00600		mg/L	1.3 (5)
	Lead	EPA 200.8	09/16/24 16:26	09/16/24 16:26	<0.00200	U	0.00200		mg/L	0.015 (5)
2410677-09	Drinking Water		Lower Kitchen Sink 2 L		Collected : 09/06/2024 7:56					
Total Metals										
	Copper	EPA 200.8	09/16/24 16:30	09/16/24 16:30	0.521		0.00600		mg/L	1.3 (5)
	Lead	EPA 200.8	09/16/24 16:30	09/16/24 16:30	0.0151		0.00200		mg/L	0.015 (5)

(5) Reg - Federal and NJ State Primary and Secondary Drinking Water Standards
X: 07010: NJ DEP

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns.
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)

Report Date: Sep 18, 2024